

**ADDENDUM NO. 1 – March 19, 2025**

**ASR Well Drilling, Development and Testing  
CIP PW 22-36**

This addendum amends the Contract Drawings and Specifications for this project as follows:

Question #1 – May a PDF editor be used to complete the bid forms, as opposed to wet ink?  
Still utilize wet ink on signature line

**Response to Question #1 – Yes, digital completion of the bid form is acceptable, as long as an authorized agent of the company provides a wet signature**

Question #2 – Are we bidding 304L SS with Full flow louvered screen as an option?

**Response to Question #2 – Well screen will be constructed of Wire Wrapped ASTM A-778 Type 316 L Stainless Steel**

Question 3 – When may the casing and gravel pack be ordered?

**Response to Question #3 – Final well design will be provided to the selected contractor within 5 working days after the last zonal sample is collected. Therefore casing and gravel pack ordered could be placed 5 days after the last zonal sample is collected.**

Question #4 – Please confirm, do drilling fluid heavies need to be hauled off or can they be discharged and left in the cutting/mud disposal area

**Response to Question #4 – All drilling fluids shall be properly disposed of offsite**

Question #5 – Due to tariffs, the steel market is currently volatile. Will the City compensate the contractor if there are unforeseen increases on casing materials?

**Response to Question #5 –The City acknowledges the current volatility in the steel market due to tariffs and other economic factors and the City is willing to evaluate changes in steel prices in coordination with the selected contractor. Any requests for price adjustments will require appropriate documentation and will be considered on a case-by-case basis in accordance with the terms of the contract.**

Question #6 – Would the City be willing to place a deposit on casing materials (if the casing order is decreased, a portion of the deposit would be appropriately refunded)?

**Response to Question #6** - The City does not place deposits on materials, including casing materials, prior to delivery and acceptance of the work. However, the City understands the challenges associated with material procurement and is open to discussing alternative solutions with the selected contractor to help mitigate potential supply chain issues. Any proposed approach must align with the terms of the contract and applicable procurement policies.

**Revision #1** – Please utilize the revised bid schedule below. The only change is related to bid item #21 (Standby time). Original bid schedule assumed 0 hours, and Bid Schedule (Revision 1) assumes 24 hours of standby time.

**ASR Well Drilling, Development and Testing,**

**CIP# PW 22-36**

**BID SCHEDULE (Revision 1)**

<b>BID ITEM</b>	<b>DESCRIPTION</b>	<b>QUANTITY</b>	<b>UNITS</b>	<b>UNIT PRICE</b>	<b>EXTENDED TOTAL</b>
1	Well Site Mobilization	Lump Sum	1		
2	Conductor Casing(36-inch O.D. X 3/8-inch Wall ASTM A-53 Grade B Steel	Linear Foot	73		
3	Pilot Borehole Drilling (17.5-inch max)	Linear Foot	980		
4	Geophysical logging	Lump Sum	1		
5	Zonal Sampling	Each	5		
6	Borehole Reaming	Linear Foot	980		
7	Blank Well Casing (ASTM A-778, Type 316L SS 18-inch I.D. X 3/8-inch wall thickness)	Linear Foot	40		
8	Blank Well Casing ASTM-A778, Type 316L SS 18-inch I.D. X 5/16-inch wall thickness)	Linear Foot	863		

9	Wire Wrapped Well Screen (ASTM A-778, Type 316L SS 18-inch I.D., with 0.060-inch Slot Size (Preliminary))	Linear Foot	130		
10	Sounding Pipes (2-inch, Schedule 40 Stainless Steel)	Linear Foot	606		
11	Gravel Fill Pipes (3-inch, Schedule 40 Stainless Steel)	Linear Foot	723		
12	Gravel Envelope – Glass Beads (SiLi 4507R)	Linear Foot	350		
13	Annular Seal	Linear Foot	700		
14	Well Development	Lump Sum	1		
15	Install/Remove Test Pump	Lump Sum	1		
16	Well and Aquifer Testing	Hour	24		
17	Plumbness and Alignment Testing and Well Video	Lump Sum	1		
18	Dynamic Flowmeter (Spinner) Testing	Lump Sum	1		
19	Disinfection of Well	Lump Sum	1		
20	Containment and Disposal of Drill Cuttings and Well Discharge Water	Lump Sum	1		
21	Standby time	Hour	24		
	<b>TOTAL BID</b>				\$

**TOTAL BID :** \_\_\_\_\_

**TOTAL BID IN WORDS :** \_\_\_\_\_

**Revision #2 – Please utilize the revised Bidder’s Bond Form Below. The only change is related to the surety bond. Original Bidder’s bond included a dollar amount, and this revision assumes Ten percent (10%) of the total amount of the bid. In addition, the Bidders Bond should be notarized.**

**Section 00300**

**ASR Well Drilling, Development and Testing**

**BID Proposal Forms**

**BIDDER'S BOND**

**KNOW ALL MEN BY THESE PRESENTS:**

THAT WE \_\_\_\_\_

as PRINCIPAL, and \_\_\_\_\_

as SURETY are held; and firmly bond unto the City of Lathrop in the penal sum of TEN PERCENT (10%) OF THE TOTAL AMOUNT OF THE BID of the Principal above named, submitted by the Principal to the City of Lathrop for the work described below, for the payment of which sum in lawful money of the United States, well and truly to be made to the City of Lathrop to which the bid was submitted, we bind ourselves, our heirs, executors, administrators and successors, jointly and severally, firmly by those presents. In no case shall the liability of the surety hereunder exceed the sum of \$ **Ten percent (10%) of the total amount of the bid.**

**THE CONDITION OF THIS OBLIGATION IS SUCH,**

**THAT, WHEREAS,** the Principal has submitted the above mentioned bid to the City of Lathrop for certain construction specifically described as follows, for which bids are to be opened at the City Hall, 390 Towne Centre Drive, Lathrop, CA: **ASR Well Drilling, Development and Testing, Development and Testing, CIP# PW 22-36.**

**NOW, THEREFORE,** if the Principal is awarded the contract and within the time and manner required under the specifications, after the prescribed forms are presented to him for signature enters into a written contract in the prescribed form, in accordance with the bid, and files two bonds with the City, one to guarantee faithful performance, and the other to guarantee payment for labor and materials as required by law, then this obligation shall be null and void; otherwise, it shall be and remain in full force.

**IN WITNESS WHEREOF**, we have hereunto set our hands and seals on this \_\_\_\_\_ day of \_\_\_\_\_, 2025.

\_\_\_\_\_ (Seal)

\_\_\_\_\_ (Seal)

\_\_\_\_\_ (Seal)

\_\_\_\_\_ (Seal)

Address: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

NOTE: Signatures of those executing for the surety must be properly acknowledged.

When submitting the bid for the project, the Contractor must acknowledge receipt of the addendum.

Recommended by: Greg Gibson 3.19.25  
Greg Gibson, PE Date  
Senior Civil Engineer

Approved by: Brad Taylor 3/19/2025  
Brad Taylor, PE Date  
City Engineer